



## CITY OF DELTONA FIRE DEPARTMENT

### Fire Safety Division

Phone (386) 878-8655/8656 Fax (386) 878-8651

Circle One or both:

**Friday, 10/21/16**      **Saturday, 10/22/16**

#### OFFICE USE ONLY

##### Items:

Pop Up:	Y	N
Pre-Packaged Food:	Y	N
Cooking on site:	Y	N
Handouts:	Y	N
Generator:	Y	N
Elec Gas		
Misc:		

### **SPECIAL EVENTS VENDOR PRE - INSPECTION CHECKLIST**

The following items are required inspections by the Deltona Fire Department, **Fire Safety Division** for the below listed special event. **Deadline for applications and inspections are Friday, October 14, 2016, with NO Exceptions.** Vendors are encouraged to call with any questions. **ALL VENDORS ARE REQUIRED TO CALL 386-878-8655 or 386-878-8656, TO SCHEDULE REQUIRED INSPECTIONS. FAILURE TO DO SO, MAY RESULT IN THE VENDOR BEING SUSPENDED AND/OR REVOKED FROM EVENT (this includes the day of the event).**

Event Name: 2016 Spooktacular Permit #: SE 16-016

Event Address: 1200 Saxon Blvd – Soccer Complex Type Permit: Food/Other Vendor

Vendor Name & Contact: \_\_\_\_\_ Phone Number: \_\_\_\_\_

E-mail: \_\_\_\_\_@\_\_\_\_\_

#### **SITE/ACCESS**

- ☒ Site Plan/Layout shall be submitted and approved
- ☒ Tents or membrane structures are a minimum of 10 ft between stake lines [1:25.2.3.1]
- ☐ Tents, not exceeding 1200sq ft and located in open spaces, shall not be required to be separated from each other, provided that safety precautions meet the approval of the AHJ [1:25.2.3.4]
- ☒ Tent fabrics shall meet the flame propagation performance criteria contained in NFPA 701, *Standard Methods for Fire Tests for Flame Propagation for Textiles and Films*. [1:25.2.2.1] A copy of the flame resistant certificate shall be submitted along with the vendor application. Affixed to each tent there shall be a flame resistant tag/label.
- ☐ Portable fire extinguishers of approved types shall be furnished and maintained in tents and vendor booths in such quantity and in such locations as directed by the AHJ. [1:25.2.5] A minimum of one portable fire extinguisher with a rating of not less than **3A-40B:C**, provided
- ☒ Fire extinguishers are properly inspected and **have current certification**
- ☒ Fire department access is not less than 20 ft of unobstructed width between rows [1:18.2.3.4.1.1]
- ☐ The finished ground level enclosed by any tent, and the finished ground level of not less than 10 ft outside of the tent is clear of combustible material or vegetation [1:25.2.4.1]
- ☒ Smoking shall not be permitted in any tent. [1:25.2.4.2] **"NO SMOKING"** signs posted at 20 ft intervals around the perimeter of the tent
- ☒ **NO open ground fire shall be allowed.**

#### **COOKING/CONCESSIONS/APPLIANCES**

- ☐ A minimum of one portable fire extinguisher, with a minimum rating of **3A:40-B:C**, shall be provided for each concession stand
- ☐ Concession stands utilized for cooking shall have a minimum of 10 ft of clearance on two sides and not be located within 10 ft of amusement rides or devices. [1:10.15.8]
- ☐ Cooking concessions shall provide a copy of food handler certificate



## CITY OF DELTONA FIRE DEPARTMENT

### Fire Safety Division

Phone (386) 878-8655/8656 Fax (386) 878-8651

**Circle One or both:**

#### **COOKING/CONCESSIONS/APPLIANCES** (cont'd):

- ☒ L/P / cooking fuels/generators are properly installed and protected in accordance with NFPA 54, *National Fuel Gas Code*, and NFPA 58, *Liquefied Petroleum Gas Code*  
Cylinders shall be positioned so that the discharge from the cylinder pressure relief device is located:
  - At least 3 ft (1 m) horizontally away from any building opening that is below the level of such discharge
  - At least 5 ft (1.5 m) in any direction away from any exterior source of ignition, openings into direct vent (sealed combustion system) appliances, or mechanical ventilation air intakes [58:6.3.1]
- ☒ Generators are separated from temporary membrane structures and tents by a minimum of 5 ft and are protected from contact by fencing, enclosure or other approved means [1:25.1.12.1]
- ☒ Cooking equipment used in mobile or temporary concessions that produces grease-laden vapors shall be protected by an approved commercial cooking exhaust hood and fire extinguishing system in accordance with NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*. [1:50.2.1.9] **A.50.4.3.2** *Examples of cooking equipment that produce grease-laden vapors include, but are not limited to, appliances such as deep-fat fryers, ranges, griddles, broilers, woks, tilting skillets, and braising pans. [96:A.10.1.2]*
- ☒ **Class K** portable fire extinguisher provided as secondary backup to commercial cooking fire extinguishing system [1:50.4.4.1]
- ☒ Fire Extinguisher(s)/Suppression System(s) properly installed, inspected and certified
- ☒ **NO deep fat, stoves and/or turkey fryers shall be allowed**
- ☒ Enclosed areas meet egress requirements

#### **GENERAL FIRE SAFETY**

- ☐ **Life Safety Evaluation.** The AHJ shall be permitted to order a life safety evaluation in accordance with 10.15.3. [1:10.15.3]
- ☒ **Electrical Equipment.** All electrical appliances, fixtures, equipment, or wiring shall be installed and maintained in accordance with NFPA 70, *National Electrical Code*. [1:10.15.7] [1:11.1.2]
- ☐ **Standby Fire Personnel.** Where required by the AHJ, standby fire personnel shall be provided and comply with 1.17.15. [1:10.15.4]
- ☐ **Communications.** Where required by the AHJ, a method of notifying the fire department in the event of an emergency shall be provided and readily available to the public. [1:10.15.9]
- ☒ **Internal Combustion Power Sources.** Fuel tanks shall be of adequate fuel capacity to permit uninterrupted operation during normal operating hours; refueling shall be conducted only when not in use; power sources shall be isolated from contact with the public by either physical guards, fencing, or an enclosure. [1:10.15.10]
- ☐ **Parade Floats.** Motorized parade floats and towing apparatus shall be provided with a minimum of **3A:40-B:C**, rated portable fire extinguisher readily accessible to the operator. [1:10.17.2]
- ☐ **Smoke Alarms.** A minimum of one single station smoke alarm shall be located in all stock or equipment trailers when they are used for sleeping purposes. [1:10.15.6]

**Vendor's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Fire Inspector:** \_\_\_\_\_ **Date:** \_\_\_\_\_